



## Clymer Air Ventilation Report

**Inspection Date: Spring 2021**

*HVAC systems brought up to ASHRAE standards using existing ventilation systems & additional filtration units*

Room #	Area (sq. ft.)	Type of Unit (NV200, NV900, NV2000, Vent System)	# of Functional Units in the Room	Max Filtration Sq. Ft.	Ready For Use
410	864	900	1	900	Yes
411	805	900	1	900	Yes
409	805	900	1	900	Yes
412	840	900	1	900	Yes
408	805	900	1	900	Yes
413	805	900	1	900	Yes
407	828	900	1	900	Yes
414	360	200 & Vent System	2	360	Yes
406	805	900	1	900	Yes
405	1050	900 & Vent System	2	1,050	Yes
W Bathroom	120	Separate exhaust system			Yes
M Bathroom	120	Separate exhaust system			Yes
403	726	900	1	900	Yes
G Bathroom	225	Separate exhaust system			Yes
B bathroom	200	Separate exhaust system			Yes
402	726	900	1	900	Yes
401	714	900	1	900	Yes
301	693	900	1	900	Yes

# Clymer Air Ventilation Report

**Inspection Date: Spring 2021**

*HVAC systems brought up to ASHRAE standards using existing ventilation systems & additional filtration units*

Room #	Area (sq. ft.)	Type of Unit (NV200, NV900, NV2000, Vent System)	# of Functional Units in the Room	Max Filtration Sq. Ft.	Ready For Use
302	352	Vent System	1	352	Yes
302A	368	Vent System	1	368	Yes
B Bathroom	200	Separate exhaust system			Yes
G Bathroom	216	Separate exhaust system			Yes
303	726	900	1	900	Yes
M Bathroom	120	Separate exhaust system			Yes
304	368	200	2	400	Yes
W bathroom	144	Separate exhaust system			Yes
305	693	900	1	900	Yes
306	805	900	1	900	Yes
315	286	200 & Vent System	2	286	Yes
314	384	200 & Vent System	2	384	Yes
307	828	900	1	900	Yes
313	840	900	1	900	Yes
308	805	900	1	900	Yes
312	805	900	1	900	Yes
309	805	900	1	900	Yes
310	805	900	1	900	Yes
311	805	900	1	900	Yes
211	805	900	1	900	Yes
210	805	900	1	900	Yes
209	805	900	1	900	Yes

# Clymer Air Ventilation Report

**Inspection Date: Spring 2021**

*HVAC systems brought up to ASHRAE standards using existing ventilation systems & additional filtration units*

Room #	Area (sq. ft.)	Type of Unit (NV200, NV900, NV2000, Vent System)	# of Functional Units in the Room	Max Filtration Sq. Ft.	Ready For Use
212	805	900	1	900	Yes
208	840	900	1	900	Yes
213	840	900	1	900	Yes
207	864	900	1	900	Yes
214	384	Vent System	1	384	Yes
206	840	900	1	900	Yes
215	180	200	1	200	Yes
215A	117	200	1	200	Yes
205	782	900	1	900	Yes
204	330	200	2	400	Yes
W Bathroom	144	Separate exhaust system			Yes
M Bathroom	120	Separate exhaust system			Yes
203	726	900	1	900	Yes
G Bathroom	225	Separate exhaust system			Yes
B Bathroom	200	Separate exhaust system			Yes
202	726	900	1	900	Yes
201	672	900	1	900	Yes
B Bathroom	432	Separate exhaust system			Yes
Cafeteria	3050	2000, 900, 200	3	3,100	No
G Bathroom	375	Separate exhaust system			Yes
M Bathroom	120	Separate exhaust system			Yes
W Bathroom	120	Separate exhaust system			Yes

# Clymer Air Ventilation Report

**Inspection Date: Spring 2021**

*HVAC systems brought up to ASHRAE standards using existing ventilation systems & additional filtration units*

Room #	Area (sq. ft.)	Type of Unit (NV200, NV900, NV2000, Vent System)	# of Functional Units in the Room	Max Filtration Sq. Ft.	Ready For Use
Auditorium	3700	Room taken offline- not in use			No
Tech Office	230	200	2	400	Yes
Staff lounge	360	200	2	400	Yes
105	200	200	1	200	Yes
106	394	Vent System	1	394	Yes
110	624	900	1	900	Yes
110A	468	900	1	900	Yes
109	1056	Vent System	1	1,056	Yes
107	864	900	1	900	Yes
108	840	900	1	900	Yes
104	238	Vent System	1	238	Yes
103	221	Vent System	1	221	Yes
101	221	Vent System	1	221	Yes