



Cramer Hill Elementary Air Filtration Report

Inspection Date: Spring 2021

HVAC systems brought up to ASHRAE standards using existing ventilation & filtration systems

Room #	Area	Outside air (CFM)	Occupancy limit during COVID-19	Ready for use
301	136	58	3	Yes
310	990	376	25	Yes
311	759	374	24	Yes
312	759	377	25	Yes
313	759	396	26	Yes
314	713	378	25	Yes
315	736	388	25	Yes
316	736	404	26	Yes
317	620	378	25	Yes
320	968	393	26	Yes
330	140	100	6	Yes
331	1025	354	23	Yes
Bathroom	Separate exhaust system			Yes
Bathroom	Separate exhaust system			Yes
Bathroom	Separate exhaust system			Yes
Bathroom	Separate exhaust system			Yes
339	280	150	10	Yes
341	288	163	10	Yes
343	768	356	23	Yes
342	735	334	22	Yes
345	768	332	22	Yes
347	736	358	23	Yes
344	756	340	22	Yes

Cramer Hill Elementary Air Filtration Report

Inspection Date: Spring 2021

HVAC systems brought up to ASHRAE standards using existing ventilation & filtration systems

Room #	Area	Outside air (CFM)	Occupancy limit during COVID-19	Ready for use
346	777	382	25	Yes
348	98	53	3	Yes
248	120	96	6	Yes
247	759	398	26	Yes
246	805	381	25	Yes
244	748	330	22	Yes
245	759	360	24	Yes
242	726	404	26	Yes
243	672	418	27	Yes
241	396	189	12	Yes
240	405	230	15	Yes
Bathroom	Separate exhaust system			Yes
Bathroom	Separate exhaust system			Yes
Bathroom	Separate exhaust system			Yes
Bathroom	Separate exhaust system			Yes
Blue room	54	87	5	Yes
231	882	434	28	Yes
230	250	150	10	Yes
220	1125	375	25	Yes
217	108	40	2	Yes
216	864	367	24	Yes
215	736	358	23	Yes
214	736	353	23	Yes
213	736	389	25	Yes
212	736	384	25	Yes
211	736	355	23	Yes
210	736	361	24	Yes
204	90	43	2	Yes
Gym	4928	2611	174	Yes

Cramer Hill Elementary Air Filtration Report

Inspection Date: Spring 2021

HVAC systems brought up to ASHRAE standards using existing ventilation & filtration systems

Room #	Area	Outside air (CFM)	Occupancy limit during COVID-19	Ready for use
Cafeteria	3337	812	54	Yes
Bathroom	Separate exhaust system			Yes
Bathroom	Separate exhaust system			Yes
104	90	Filtration unit installed; 200 sq ft disinfected		Yes
110	768	398	26	Yes
111	736	405	27	Yes
112	759	397	26	Yes
113	462	253	16	Yes
Bathroom	Separate exhaust system			Yes
114	400	307	20	Yes
116	150	36	2	Yes
117	165	36	2	Yes
118	225	150	10	Yes
125	260	202	13	Yes
124	169	43	2	Yes
123	165	25	1	Yes
122	182	30	2	Yes
Library	1344	440	29	Yes
Bathroom	Separate exhaust system			Yes
Bathroom	Separate exhaust system			Yes
Bathroom	Separate exhaust system			Yes
Bathroom	Separate exhaust system			Yes
139	216	97	6	Yes
141	864	450	30	Yes
140	741	465	31	Yes
142	819	421	28	Yes
143	858	169	11	Yes
145	891	438	29	Yes
144	840	422	28	Yes

Cramer Hill Elementary Air Filtration Report

Inspection Date: Spring 2021

HVAC systems brought up to ASHRAE standards using existing ventilation & filtration systems

Room #	Area	Outside air (CFM)	Occupancy limit during COVID-19	Ready for use
146	722	430	28	Yes
148	170	73	4	Yes
149	782	444	29	Yes
147	759	441	29	Yes
100	64	90	6	Yes