



McGraw Elementary Air Filtration Report

Inspection Date: Winter 2021

HVAC systems brought up to ASHRAE standards using air purification systems

Room #	Area (sq. ft.)	Type of unit (NV200 or NV900)	# of functional units in room	Max filtration sq. ft.	Ready for use
Cafeteria	2360	Independent filtration system meets safe ventilation standards			Yes
Auditorium	2040	Independent filtration system meets safe ventilation standards			Yes
1st floor bathroom	100	Separate exhaust system		100	Yes
Main office	242	200	2	400	Yes
Principal's office	100	200	1	200	Yes
1st floor bathroom	90	Separate exhaust system		90	Yes
Conference room	286	200	2	400	Yes
1st floor bathroom	95	Separate exhaust system		95	Yes
111	736	900	1	900	Yes
110	736	900	1	900	Yes
109	736	900	1	900	Yes
108	736	900	1	900	Yes
107	736	900	1	900	Yes
106	736	900	1	900	Yes
1st floor bathroom	150	Separate exhaust system		150	Yes
Teacher lounge	286	200	2	400	Yes
105	736	900	1	900	Yes

McGraw Elementary Air Filtration Report

Inspection Date: Winter 2021

HVAC systems brought up to ASHRAE standards using air purification systems

Room #	Area (sq. ft.)	Type of unit (NV200 or NV900)	# of functional units in room	Max filtration sq. ft.	Ready for use
103	880	900	1	900	Yes
102	920	900	2	1800	Yes
100	736	900	1	900	Yes
98	736	900	1	900	Yes
96	736	900	1	900	Yes
97	736	900	1	900	Yes
99	736	900	1	900	Yes
101	736	900	1	900	Yes
104	70	200	1	200	Yes
115	780	900	1	900	Yes
116	780	900	1	900	Yes
Annex bathroom	200	Separate exhaust system		200	Yes
Annex bathroom	175	Separate exhaust system		175	Yes
117	780	900	1	900	Yes
118	780	900	1	900	Yes
119b	80	200	1	200	Yes
120	800	900	1	900	Yes
121	775	900	1	900	Yes
122	744	900	1	900	Yes
124	775	900	1	900	Yes