



## Molina Annex Air Filtration Report

**Inspection Date: Winter 2021**

*HVAC systems brought up to ASHRAE standards using air purification systems*

Room #	Area (sqft)	Type of unit (NV200 or NV900)	# of functional units in room	Max filtration sq.ft.	Room safe for use
9	725	900	1	900	Yes
10	700	900	1	900	Yes
11	736	900	1	900	Yes
8	736	900	1	900	Yes
7	700	900	1	900	Yes
12	725	900	1	900	Yes
1	744	900	1	900	Yes
6	696	900	1	900	Yes
2	736	900	1	900	Yes
5	736	900	1	900	Yes
4	725	900	1	900	Yes
3	672	900	1	900	Yes
FAA	397	200	2	400	Yes
S Bathroom	16	200	0	0	Yes
G Bathroom	165	200	0	0	Yes
S Bathroom	56	200	0	0	Yes
Kitchen	336	200	2	400	Yes

# Molina Annex Air Filtration Report

Inspection Date: Winter 2021

*HVAC systems brought up to ASHRAE standards using air purification systems*

Room #	Area (sqft)	Type of unit (NV200 or NV900)	# of functional units in room	Max filtration sq.ft.	Room safe for use
B Bathroom	239	200	0	0	Yes
Gym	1800	900	2	1800	Yes
Staff Lounge	196	200	1	200	Yes
Staff space	696	900	1	900	Yes
RR	132	200	1	200	Yes
Office	130	200	1	200	Yes
Office	130	200	1	200	Yes