



Molina Lower Air Ventilation Report

Inspection Date: Spring 2021

HVAC systems brought up to ASHRAE standards using existing ventilation systems

Room #	Area (sq. ft.)	Outside Air (CFM)	Occupancy Limit During COVID-19	Ready For Use
207	1032	691	46	Yes
204	480	480 total room sq ft; maximum filtration for 900 sq ft		Yes
211	140	26	2	Yes
2nd B Bathroom	160	Separate exhaust system		Yes
2nd G Bathroom	160	Separate exhaust system		Yes
212	288	51	3	Yes
213/214	988	409	27	Yes
215	442	276	18	Yes
216	42	30	2	Yes
217	54	36	2	Yes
218	494	263	17	Yes
219	320	320 total room sq ft; maximum filtration for 900 sq ft		Yes
220	378	377	25	Yes
221	380	217	14	Yes
222	480	433	28	Yes
200	437	321	21	Yes
201	77	37	2	Yes

Molina Lower Air Ventilation Report

Inspection Date: Spring 2021

HVAC systems brought up to ASHRAE standards using existing ventilation systems

Room #	Area (sq. ft.)	Outside Air (CFM)	Occupancy Limit During COVID-19	Ready For Use
202	77	38	2	Yes
203	480	361	24	Yes
205	690	390	26	Yes
206	504	376	25	Yes
106/105	936	413	27	Yes
103/104	1032	616	41	Yes
107	988	683	45	Yes
1st B Bathroom	175	Separate exhaust system		Yes
1st G Bathroom	170	Separate exhaust system		Yes
108	728	511	34	Yes
109	788	458	30	Yes
110	1617	833	55	Yes
100	504	393	26	Yes
101	110	64	4	Yes
Custodial office	110	46	3	Yes
102	504	291	19	Yes
Main Office	396	88	5	Yes
Conference Room	231	179	11	Yes
Principal Office	162	53	3	Yes
APO Office	96	59	3	Yes