



## Pickett Air Ventilation Report

**Inspection Date: Winter 2021**

*HVAC systems brought up to ASHRAE standards using existing ventilation systems & additional filtration units*

Room #	Outside Air (CFM)	Occupancy Limit During COVID-19	Ready For Use
108	492	32	Yes
106	693	46	Yes
104	462	30	Yes
102	619	41	Yes
100	626	41	Yes
Mail/Copy room	565	37	Yes
103	400 total room sq ft; maximum filtration for 400 sq ft		Yes
105	414	27	Yes
107	459	30	Yes
Bathroom	Separate exhaust system		Yes
Computer repair room	584	38	Yes
Laptop storage	469	31	Yes
Conference room	510	34	Yes
200	712	47	Yes
201	293	19	Yes
203	437	29	Yes
2nd Flr Bathroom	Separate exhaust system		Yes
205	515	34	Yes
202	700	46	Yes
204	730	48	Yes
206	655	43	Yes
308	385	25	Yes
3rd flr. Bathroom	Separate exhaust system		Yes

# Pickett Air Ventilation Report

Inspection Date: Winter 2021

*HVAC systems brought up to ASHRAE standards using existing ventilation systems & additional filtration units*

Room #	Outside Air (CFM)	Occupancy Limit During COVID-19	Ready For Use
306	388	25	Yes
305	356	23	Yes
304	617	41	Yes
303	560	37	Yes
302	547	36	Yes
301	223	14	Yes
300	574	38	Yes
300A	89	5	Yes
300B	294	19	Yes
300C	135	9	Yes
122	389	25	Yes
120	580	38	Yes
118	684	45	Yes
116	474	31	Yes
114	710	47	Yes
112	342	22	Yes
110	359	23	Yes
NST	1317	87	Yes
208	226	15	Yes
208A	83	5	Yes
210	243	16	Yes
212	424	28	Yes
213	700 total room sq ft; maximum filtration for 900 sq ft		Yes
214	420	28	Yes
215	493	32	Yes
216	531	35	Yes
218	445	29	Yes
220	442	29	Yes

# Pickett Air Ventilation Report

Inspection Date: Winter 2021

*HVAC systems brought up to ASHRAE standards using existing ventilation systems & additional filtration units*

Room #	Outside Air (CFM)	Occupancy Limit During COVID-19	Ready For Use
222	490	32	Yes
219	372	24	Yes
217	349	23	Yes
221	182 total room sq ft; maximum filtration for 200 sq ft		Yes
2nd Flr Bathroom	Separate exhaust system		Yes
209	413	27	Yes
207	392	26	Yes
320	743	49	Yes
319/319A	354	23	Yes
318	607	40	Yes
317	762	50	Yes
316	782	52	Yes
315	806	53	Yes
314	470	31	Yes
313	511	34	Yes
312	539	35	Yes
311	572	38	Yes
3rd Flr. Bathroom	Separate exhaust system		Yes
310	516	34	Yes
Gym, PE office, locker rooms home and away	11686	779	Yes
Cafeteria	1594	106	Yes
Fitness Center and bathroom	1870 total room sq ft; maximum filtration for 2000 sq ft		Yes
309	180 total room sq ft; maximum filtration for 200 sq ft		Yes
221A	256 total room sq ft; maximum filtration for 400 sq ft		Yes
100A	228 total room sq ft; maximum filtration for 400 sq ft		Yes
100B	140 total room sq ft; maximum filtration for 200 sq ft		Yes
100C	204 total room sq ft; maximum filtration for 400 sq ft		Yes

# Pickett Air Ventilation Report

Inspection Date: Winter 2021

*HVAC systems brought up to ASHRAE standards using existing ventilation systems & additional filtration units*

Room #	Outside Air (CFM)	Occupancy Limit During COVID-19	Ready For Use
101	120 total room sq ft; maximum filtration for 200 sq ft		Yes
109	200 total room sq ft; maximum filtration for 200 sq ft		Yes
105A	140 total room sq ft; maximum filtration for 200 sq ft		Yes
105B	140 total room sq ft; maximum filtration for 200 sq ft		Yes
105C	110 total room sq ft; maximum filtration for 200 sq ft		Yes
BE office	Storage area no unit necessary		Yes
Shark Tank	531	35	Yes
Locker room	1774 total room sq ft; maximum filtration for 1800 sq ft		Yes