



## Prep Elementary Air Ventilation Report

**Inspection Date: Spring 2021**

*HVAC systems brought up to ASHRAE standards using existing ventilation systems & additional filtration units*

Room #	Area	Outside Air (CFM)	Occupancy limit during COVID-19	Ready For Use
341	312	261	17	yes
348	330	292	19	yes
343	638	434	28	yes
350	860	450	30	yes
345	638	453	30	yes
347	960	424	28	yes
349	638	432	28	yes
351	638	410	27	yes
353	660	467	31	yes
Open space	725	82	5	yes
311	660	427	28	yes
309	638	415	27	yes
307	638	417	27	yes
305	748	385	25	yes
303	638	420	28	yes
312	660	462	30	yes
310	210	72	4	yes
301	792	466	31	yes
3rd floor bath		Separate exhaust system		yes
3rd floor bath		Separate exhaust system		yes
3rd floor bath		Separate exhaust system		yes
3rd floor bath		Separate exhaust system		yes
3rd floor bath		Separate exhaust system		yes

# Prep Elementary Air Ventilation Report

**Inspection Date: Spring 2021**

*HVAC systems brought up to ASHRAE standards using existing ventilation systems & additional filtration units*

Room #	Area	Outside Air (CFM)	Occupancy limit during COVID-19	Ready For Use
3rd floor bath		Separate exhaust system		yes
2nd floor bath		Separate exhaust system		yes
2nd floor bath		Separate exhaust system		yes
2nd floor bath		Separate exhaust system		yes
210	182	81	5	yes
201	616	410	27	yes
212	660	407	27	yes
203	720	388	25	yes
Open space	264	75	5	yes
207	656	392	26	yes
209	946	453	30	yes
211	946	448	29	yes
Open space	294	52	3	yes
251	484	316	21	yes
249	946	463	30	yes
247	748	425	28	yes
245	286	Filtration unit installed; 900 sq ft disinfected		yes
243	308	313	20	yes
241	550	386	25	yes
248	600	178	11	yes
248B	150	55	3	yes
248C	150	45	3	yes
248D	195	50	3	yes
1st floor bath		Separate exhaust system		yes
1st floor bath		Separate exhaust system		yes
141	3159	241	16	yes
1st floor bath		Separate exhaust system		yes
1st floor bath		Separate exhaust system		yes

# Prep Elementary Air Ventilation Report

Inspection Date: Spring 2021

*HVAC systems brought up to ASHRAE standards using existing ventilation systems & additional filtration units*

Room #	Area	Outside Air (CFM)	Occupancy limit during COVID-19	Ready For Use
148	408	Filtration unit installed; 900 sq ft disinfected		yes
143	946	420	28	yes
150	580	467	31	yes
Open space	336	162	10	yes
147	770	388	25	yes
149	286	151	10	yes
151	240	149	9	yes
153	462	273	18	yes
109	814	439	29	yes
107	792	432	28	yes
Open space	406	115	7	yes
103	792	445	29	yes
110	836	391	26	yes
107	616	432	28	yes
Cafeteria	3124	1711	114	yes
Gym	4343	2115	141	yes