



Prep Middle Air Ventilation Report

Inspection Date: Spring 2021

HVAC systems brought up to ASHRAE standards using existing ventilation systems & additional filtration units

Room #	Area (sq. ft.)	Type of unit (NV200, NV900, or NV2000)	# of functional units in room	Max filtration sq.ft.	Ready for use
300	650	900	1	900	Yes
299	90	200	1	200	Yes
301	560	900	1	900	Yes
302	460	900	1	900	Yes
291	600	900	1	900	Yes
296	841	900	1	900	Yes
294	812	900	1	900	Yes
292	780	900	1	900	Yes
290	775	900	1	900	Yes
288	775	900	1	900	Yes
2nd Girls bathroom	450	Separate exhaust system			Yes
286	750	900	1	900	Yes
285	150	200	1	200	Yes
284	750	900	1	900	Yes
282	775	900	1	900	Yes
Cafeteria	1220	900	2	1800	Yes
190	806	900	1	900	Yes
Weight room	ROOM TAKEN OFFLINE - Not in use at this time				No
1st Floor office	150	200	1	200	Yes
Admin area	336	200	2	400	Yes
194	650	900	1	900	Yes

Prep Middle Air Ventilation Report

Inspection Date: Spring 2021

HVAC systems brought up to ASHRAE standards using existing ventilation systems & additional filtration units

Room #	Area (sq. ft.)	Type of unit (NV200, NV900, or NV2000)	# of functional units in room	Max filtration sq.ft.	Ready for use
193	210	200	2	400	Yes
191	100	200	1	200	Yes
192	812	900	1	900	Yes
1st Boys bathroom	300	Separate exhaust system			Yes
190	806	900	1	900	Yes
188	775	900	1	900	Yes
186	775	900	1	900	Yes
184	775	900	1	900	Yes
182	775	900	1	900	Yes
199	336	200	2	400	Yes
1st Boys bathroom	198	Separate exhaust system			Yes
1st Girls bathroom	190	Separate exhaust system			Yes