



## Smedley Air Filtration Report

Inspection Date: Winter 2021

*HVAC systems brought up to ASHRAE standards using air purification systems*

Room #	Area (sqft)	Type of unit (NV200 or NV900)	# of functional units in room	Max filtration sq.ft.	Room safe for use
314	840	900	1	900	Yes
308	667	900	1	900	Yes
313	754	900	1	900	Yes
307	667	900	1	900	Yes
Gbath	190	200	1	200	Yes
306	644	900	1	900	Yes
310	660	900	1	900	Yes
311A	150	200	1	200	Yes
305	621	900	1	900	Yes
309	667	900	1	900	Yes
304	690	900	1	900	Yes
303a	680	900	1	900	Yes
303	299	200	2	400	Yes
303b	104	200	1	200	Yes
303c	112	200	1	200	Yes
303d	250	200	2	400	Yes
303e	98	200	1	200	Yes
Staff Bath	150	200	1	200	Yes
Bbath	152	200	1	200	Yes
302	638	900	1	900	Yes
301	667	900	1	900	Yes
312	754	900	1	900	Yes
311	840	900	1	900	Yes
208	667	900	1	900	Yes
207	638	900	1	900	Yes
206	644	900	1	900	Yes
Gbath	160	200	1	200	Yes
210	190	200	1	200	Yes
Staff Bath	150	200	1	200	Yes
205	621	900	1	900	Yes
209	667	900	1	900	Yes
204	690	900	1	900	Yes
203a	171	200	1	200	Yes

## Smedley Air Filtration Report

Inspection Date: Winter 2021

*HVAC systems brought up to ASHRAE standards using air purification systems*

Room #	Area (sqft)	Type of unit (NV200 or NV900)	# of functional units in room	Max filtration sq.ft.	Room safe for use
203	644	900	1	900	Yes
202	667	900	1	900	Yes
201	607	900	1	900	Yes
108	638	900	1	900	Yes
107	638	900	1	900	Yes
AP	190	200	1	200	Yes
Staff Bath	150	200	1	200	Yes
106	644	900	1	900	Yes
105	230	200	2	400	Yes
105a	65	200	1	200	Yes
105b	170	200	1	200	Yes
109	609	900	1	900	Yes
APO	186	200	1	200	Yes
104	644	900	1	900	Yes
103	644	900	1	900	Yes
103a	195	200	1	200	Yes
nurse	140	200	1	200	Yes
102	667	900	1	900	Yes
101	667	900	1	900	Yes
Gym	3465	Independent filtration system meets safe ventilation standards			Yes
105aa	247	200	2	400	Yes
105bb	480	900	1	900	Yes
105cc	325	200	2	400	Yes
B1.5	272	200	2	400	Yes
Bath	252	200	2	400	Yes
PO	88	200	1	200	Yes
RSO	300	200	2	400	Yes
SEO	240	200	2	400	Yes
Pod 2D	150	200	1	200	Yes
Pod 2E	120	200	1	200	Yes
Pod 2F	120	200	1	200	Yes
Cafeteria	2788	Independent filtration system meets safe ventilation standards			Yes
Kit	120	200	1	200	Yes
B2	528	900	1	900	Yes
B4	272	200	2	400	Yes
B3	200	200	1	200	Yes
B5	250	200	2	400	Yes
B6	300	200	2	400	Yes
ESL	210	200	2	400	Yes
Library	598	900	1	900	Yes