



## John Wister Air Ventilation Report

**Inspection Date: Spring 2021**

*HVAC systems brought up to ASHRAE standards using existing ventilation systems & additional filtration units*

Room #	Area (sq. ft.)	Type of Unit (NV200, NV900, NV2000, Vent)	# of Functional Units in the Room	Max Filtration Sq. Ft.	Ready For Use
303	828	900	1	900	Yes
307	798	900	1	900	Yes
305	756	900	1	900	Yes
304	888	900	1	900	Yes
303	777	900	1	900	Yes
302	851	900	1	900	Yes
G Bathroom	104	Separate exhaust system			Yes
300	798	900	1	900	Yes
S Bathroom	415	Separate exhaust system			Yes
B Bathroom	112	Separate exhaust system			Yes
301	396	Vent System	1	396	Yes
201	396	Vent System	1	396	Yes
B Bathroom	104	Separate exhaust system			Yes
211	625	900	1	900	Yes
G Bathroom	108	Separate exhaust system			Yes
210	754	Vent System	1	754	Yes

# John Wister Air Ventilation Report

**Inspection Date: Spring 2021**

*HVAC systems brought up to ASHRAE standards using existing ventilation systems & additional filtration units*

Room #	Area (sq. ft.)	Type of Unit (NV200, NV900, NV2000, Vent	# of Functional Units in the Room	Max Filtration Sq. Ft.	Ready For Use
212	754	900	1	900	Yes
209B	319	200	2	400	Yes
209D	294	200	2	400	Yes
209C	308	Vent System	1	308	Yes
213	754	900	1	900	Yes
208	650	900	1	900	Yes
214	754	900	1	900	Yes
209A	140	200	1	200	Yes
215	126	200	1	200	Yes
202	814	900	1	900	Yes
B Bathroom	91	Separate exhaust system			Yes
S Bathroom	36	Separate exhaust system			Yes
200	874	900	1	900	Yes
G Bathroom	104	Separate exhaust system			Yes
203	777	900	1	900	Yes
204	621	900	1	900	Yes
204A	144	200	1	200	Yes
205	851	900	1	900	Yes
207	798	900	1	900	Yes
206	828	900	1	900	Yes

# John Wister Air Ventilation Report

**Inspection Date: Spring 2021**

*HVAC systems brought up to ASHRAE standards using existing ventilation systems & additional filtration units*

Room #	Area (sq. ft.)	Type of Unit (NV200, NV900, NV2000, Vent	# of Functional Units in the Room	Max Filtration Sq. Ft.	Ready For Use
106	425	900	1	900	Yes
103	798	900	1	900	Yes
104A	102	200	1	200	Yes
101	777	900	1	900	Yes
107A	398	200	2	400	Yes
107B	144	200	1	200	Yes
102	168	200	1	200	Yes
102A	150	200	1	200	Yes
115A	135	200	1	200	Yes
115B	88	200	1	200	Yes
115C	286	200	2	400	Yes
114A	160	200	1	200	Yes
B Bathroom	208	Separate exhaust system			Yes
S Bathroom	64	Separate exhaust system			Yes
G Bathroom	425	Separate exhaust system			Yes
100	735	900	1	900	Yes
108	1040	900 & Vent System	2	1,040	Yes
111	1100	900 & Vent System	2	1,100	Yes
110	400	Vent System	1	400	Yes
B Bathroom	190	Separate exhaust system			Yes
109	1040	900 & Vent System	2	1,040	Yes

# John Wister Air Ventilation Report

Inspection Date: Spring 2021

*HVAC systems brought up to ASHRAE standards using existing ventilation systems & additional filtration units*

Room #	Area (sq. ft.)	Type of Unit (NV200, NV900, NV2000, Vent	# of Functional Units in the Room	Max Filtration Sq. Ft.	Ready For Use
G Bathroom	378	Separate exhaust system			Yes
Gym	3427	Vent System	Occupancy during COVID-19 = 102		Yes
Auditorium	3172	Vent System	Occupancy during COVID-19 = 135		Yes