



## Cleveland Elementary Air Filtration Report

**Inspection Date: Winter 2021**

*HVAC systems brought up to ASHRAE standards using air purification systems*

Room #	Area (sq. ft.)	Type of unit (NV200 or NV900)	# of functional units in room	Max filtration sq. ft.	Ready for use
L308	775	900	1	900	yes
L301	648	900	1	900	yes
L302	775	900	1	900	yes
L303	725	900	1	900	yes
L304	725	900	1	900	yes
L306	775	900	1	900	yes
L305	648	900	1	900	yes
W bathroom	80	Separate exhaust system		80	yes
L307	621	900	1	900	yes
M bathroom	60	Separate exhaust system		60	yes
L309	725	900	1	900	yes
L310	725	900	1	900	yes
L311	775	900	1	900	yes
AO office	171	200	1	200	yes
B bathroom	260	Separate exhaust system		260	yes
G bathroom	240	separate exhaust system		240	yes

# Cleveland Elementary Air Filtration Report

**Inspection Date: Winter 2021**

*HVAC systems brought up to ASHRAE standards using air purification systems*

Room #	Area (sq. ft.)	Type of unit (NV200 or NV900)	# of functional units in room	Max filtration sq. ft.	Ready for use
Office	160	200	1	200	yes
311	744	900	1	900	yes
B bathroom	90	Separate exhaust system		90	yes
301	782	900	1	900	yes
302	713	900	1	900	yes
G bathroom	143	Separate exhaust system		143	yes
303	744	900	1	900	yes
Dean's office	234	200	2	400	yes
304	744	900	1	900	yes
305	792	900	1	900	yes
306	806	900	1	900	yes
307	696	900	1	900	yes
206	775	900	1	900	yes
207	713	900	1	900	yes
205	759	900	1	900	yes
204	768	900	1	900	yes
203	744	900	1	900	yes
202	713	900	1	900	yes
G bathroom	143	Separate exhaust system		143	yes

# Cleveland Elementary Air Filtration Report

**Inspection Date: Winter 2021**

*HVAC systems brought up to ASHRAE standards using air purification systems*

Room #	Area (sq. ft.)	Type of unit (NV200 or NV900)	# of functional units in room	Max filtration sq. ft.	Ready for use
201	782	900	1	900	yes
B bathroom	99	Separate exhaust system		99	yes
Copy room	98	200	1	200	yes
Office	230	200	2	400	yes
106	744	900	1	900	yes
107	744	900	1	900	yes
105	759	900	1	900	yes
104	744	900	1	900	yes
103	744	900	1	900	yes
102	713	900	1	900	yes
G bathroom	143	Separate exhaust system		143	yes
101	782	900	1	900	yes
B bathroom	99	Separate exhaust system		99	yes
111	744	900	1	900	yes
B office	114	200	1	200	yes
Staff lounge	360	200	1	200	yes
ML	744	900	1	900	yes
SW	378	200	2	400	yes
Bathroom	100	Separate exhaust system		100	yes

# Cleveland Elementary Air Filtration Report

**Inspection Date: Winter 2021**

*HVAC systems brought up to ASHRAE standards using air purification systems*

Room #	Area (sq. ft.)	Type of unit (NV200 or NV900)	# of functional units in room	Max filtration sq. ft.	Ready for use
Bathroom	120	Separate exhaust system		120	yes
B bathroom	120	Separate exhaust system		120	yes
G bathroom	120	Separate exhaust system		120	yes
B110	770	900	1	900	yes
B109	770	900	1	900	yes
Cafeteria	1748	Space not in use			no
Small Cafeteria	950	900 and 200	2	1100	yes
W bathroom	32	Separate exhaust system		32	yes
G bathroom	120	Separate exhaust system		120	yes
BE office	200	200	1	200	yes
Nurse	160	200	1	200	yes
Tech office	506	900	1	900	yes
SQA office	128	200	1	200	yes
W bathroom	48	Separate exhaust system		48	yes
M bathroom	64	Separate exhaust system		64	yes
Gym	4028	2000, 900, & 200	5	4200	yes
Auditorium	4636	900 & 200	6	4700	yes
Conference room	384	200	2	400	yes
AR office	275	200	2	400	yes

# Cleveland Elementary Air Filtration Report

Inspection Date: Winter 2021

*HVAC systems brought up to ASHRAE standards using air purification systems*

Room #	Area (sq. ft.)	Type of unit (NV200 or NV900)	# of functional units in room	Max filtration sq. ft.	Ready for use
Principal's office	228	200	2	400	yes
APO office	182	200	1	200	yes