



## Hardy Williams Elementary Air Filtration Report

**Inspection Date: Winter 2021**

*HVAC systems brought up to ASHRAE standards using air purification systems*

Room #	Area (sq. ft.)	Type of unit (NV200 or NV900)	# of functional units in room	Max filtration sq. ft.	Ready for use
321	660	900	1	900	yes
320	672	900	1	900	yes
316	748	900	1	900	yes
315	638	900	1	900	yes
313	638	900	1	900	yes
312	638	900	1	900	yes
307	638	900	1	900	yes
AP office	180	200	1	200	yes
305	660	900	1	900	yes
304	858	900	1	900	yes
303	480	900	1	900	yes
302	682	900	1	900	yes
301	890	900	1	900	yes
205	660	900	1	900	yes
206	638	900	1	900	yes
207	672	900	1	900	yes
208	638	900	1	900	yes

# Hardy Williams Elementary Air Filtration Report

**Inspection Date: Winter 2021**

*HVAC systems brought up to ASHRAE standards using air purification systems*

Room #	Area (sq. ft.)	Type of unit (NV200 or NV900)	# of functional units in room	Max filtration sq. ft.	Ready for use
Teachers Lounge	200	200	1	200	yes
210	660	900	1	900	yes
215	638	900	1	900	yes
211	400	900	1	900	yes
217	651	900	1	900	yes
220	638	900	1	900	yes
221	748	900	1	900	yes
108	814	900	1	900	yes
Lactation room	250	200	2	400	yes
109	748	900	1	900	yes
110	667	900	1	900	yes
113	704	900	1	900	yes
116	890	900	1	900	yes
118	638	900	1	900	yes
119	682	900	1	900	yes
Gym	2700	900, 2000	2	2900	yes
Cafeteria	2030	900	3	2700	yes
Dean's office	140	200	1	200	yes
M03	90	200	1	200	yes
Conference room	135	200	1	200	yes
APO office	105	200	1	200	yes
Principal's office	90	200	1	200	yes